



NOTES:

1 1/2", 1", & 3/4" SERVICE LINES SHALL BE TYPE K COPPER.

2" SERVICE LINES SHALL BE K COPPER OR P.E. 3408 SDR 9 (CTS).

3/4", 1", 1 1/2", & 2" FITTINGS SHALL BE FLARE TYPE OR COMPRESSION PACK JOINT FITTINGS. (NO SOLDER FITTINGS)

TAPPING INTO MAIN LINE WILL BE TAPERED THREAD TO FLARED CORPORATION. MUELLER TYPE H-1500 TAP MADE BY MUELLER B-100, B-101, OR A-3 PRESSURE TAPPING MACHINE OR EQUAL.

CORPORATIONS TAPPED INTO WATER MAIN MUST HAVE A MINIMUM OF 24" SEPARATION BETWEEN CORPORATION STOPS.

APPROVED _____

CITY ENGINEER

REVISED: 1/2/09

**STANDARD WATER
SERVICE**

CITY OF LANCASTER, OHIO
DEPARTMENT OF ENGINEERING

STANDARD
CONSTRUCTION DRAWING

DWG. BY: ...MAC.....

CHK'D BY:

FILE NUMBER

W-2