



NOTES:

CURB STOP AND METER SET TO BE INSTALLED WITHIN A MINIMAL DISTANCE TO PROPERTY LINE AS APPROVED BY LANCASTER DIVISION OF WATER.

METER TO BE SET AT RIGHT ANGLES TO RIGHT-OF -WAY AND MUST BE LEVEL AND CENTERED WITH YOLK VALVES UPRIGHT.

METER ENCLOSURE DIAMETER SHALL BE 18" FOR 5/8", 3/4", AND 1" METERS.

METER ENCLOSURE COVER TO BE FORD METER BOX CO. NUMBER W-3 OR AN APPROVED EQUAL WITH AN 11 1/2" OPENING.

APPROVED _____

 CITY ENGINEER

STANDARD OUTSIDE
 METER SET FOR 5/8",
 3/4", AND 1"
 METERS/BACKFLOW
 PREVENTERS

CITY OF LANCASTER, OHIO
 DEPARTMENT OF ENGINEERING

STANDARD
 CONSTRUCTION DRAWING

DWG. BY: ...MAC.....
 CHK'D BY:

FILE NUMBER
 W-32

REVISED: 1/2/09