



∙2'

Curb or Combined Curb and Gutter shall be taken out and replaced with concrete, separated from the ramp by 1/2" premolded expansion joint per ASTM D-994. When less than 5' of a curb section remains after the curb cut is located, it shall be removed and replaced. Curb removal may be by sawing only if pre-approved by the Engineer.

Fills if required shall be of earth compacted in 2" layers, or of Item 304, Aggregate Base, Compacted in layers not Exceeding 4".

Driveways and Sidewalks shall be Constructed of plain portland cement concrete, Item 452, 5% to 8% Air Entrained, (CL.C., Sect. 499) Per C.Y. and 3" Max. slump (as shown in details.)

Expansion joints shall be placed to form utility strips where required, and wherever new concrete touches existing construction. Expansion material shall be 1/2" asphalt, non-extruding and meet ASTM D-994. It shall extend the full-depth of the concrete.

Forms shall consist of wood 2" nominal thickness or metal of equal strength.

A standard curing compound shall be properly applied immediatley after finish.

Item numbers Construction and Material Specifications of Lancaster, Ohio, current Edition. All work shall be done in accordance with these specifications.

Notify Department of Engineering when forms will be ready for inspection, at least 24 hours before concrete is to be placed. Telephone 687—6614. In no case shall concrete be placed without approval of form work by the inspector & Curb shall be constructed in minimum 5' sections and maximum 10' sections.

No concrete shall be placed until temperature is 35° F. Min. Concrete shall be protected in accordance with section 451.10 of Item 451.

Where the adjoining sidewalk is less than 5', the walk portion of the driveway shall not be less than 5'.

APPROVED 3-11-13

STANDARD DRIVEWAY

(COMERCIAL) ON PUBLIC R/W & SPECIFICATIONS (NON ARTERIAL STREET)

REVISED: 8 MAR 13

CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING

CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING

STANDARD DRIVEWAY

(COMERCIAL) ON PUBLIC STANDARD CONSTRUCTION DRAWING

CHK'D BY: DDK FILE NUMBER P-23