



NOTE: REFER TO ARCHITECTURAL AND ELECTRICAL PLANS FOR BUILDING CONSTRUCTION DETAILS

APPROVED DOUBLE CHECK BACKFLOW DEVICE MODEL 1015 WITH DETECTOR CHECK OR APPROVED REDUCED PRESSURE BACKFLOW DEVICE MODEL 1013 WITH DETECTOR CHECK

OS&Y GATE VALVE (TYP.)

STRAINER

WATER METER

18" MIN

STEEL SLEEVE AND LINK SEAL (TYP.)

HARDWOOD BLOCKING AT EACH GATE VALVE (TYP.)

BLOCK FOUNDATION WALL

REINFORCED CONCRETE WALL FOOTING

DUCTILE WATER LINE (TYP.)

DUCTILE WATER LINE (TYP.)

APPROVED _____

 CITY ENGINEER

REVISED: 8/15/13

4", 6", 8" & 12"
 RESIDENTIAL/COMMERCIAL
 WATER METER/BACKFLOW
 PREVENTER ENCLOSURE

CITY OF LANCASTER, OHIO
 DEPARTMENT OF ENGINEERING

STANDARD
 CONSTRUCTION DRAWING

DWG. BY: ...MAC...
 CHK'D BY:

FILE NUMBER
 W-27A