

Sample Location	Results	Month																	
		Feb-2016	Mar-2016	Apr-2016	May-2016	Jun-2016	Jul-2016	Aug-2016	Sep-2016	Oct-2016	Nov-2016	Dec-2016	Jan-2017	Apr-2017	Jul-2017	Oct-2017	Feb-2018	Jul-2018	Apr-2019
4	ug/L	15.3	14.0	9.7	6.7	7.7	4.1	7.9	O.O.S.	O.O.S.	O.O.S.	O.O.S.	O.O.S.	O.O.S.	13.5	14.0	7.0	13.5	14.0
16	ug/L	12.7	12.0	13.9	5.4	7.1	5.4	8.1	4.5	5.0	7.7	7.6	5.3	7.4	19.2	13.0	11.0	19.2	13.0
18	ug/L	13.8	13.0	11.8	6.7	7.8	5.0	7.9	3.6	5.7	BDL	9.3	7.1	7.8	13.9	15.0	12.0	13.9	13.0
19	ug/L	12.0	12.0	10.7	4.9	6.3	3.8	8.6	3.9	4.4	5.6	8.0	5.6	7.3	14.6	14.0	12.0	14.6	14.0
20	ug/L	13.2	10.0	7.4	3.2	BDL	5.0	BDL	6.8	4.4	6.9	4.8	3.9	BDL	5.7	3.5	12.0	5.7	O.O.S.
22	ug/L	14.1	11.0	7.8	3.1	5.4	BDL	6.5	3.4	4.6	6.7	4.2	4.2	6.3	12.6	12.0	O.O.S.	12.6	O.O.S.
25	ug/L	12.9	12.0	9.0	5.0	5.5	BDL	O.O.S.	O.O.S.	O.O.S.	O.O.S.	O.O.S.	O.O.S.	O.O.S.	8.9	3.0	4.0	8.9	12.0
26	ug/L	13.7	11.0	7.8	3.7	4.1	6.1	8.3	6.6	5.7	7.4	4.5	5.2	10.0	10.5	11.0	10.0	10.5	15.0
27	ug/L	13.5	18.0	9.0	4.3	3.7	4.7	8.0	5.5	4.9	7.7	8.5	BDL	5.5	13.2	15.0	11.0	13.2	12.0
28	ug/L	14.0	11.0	6.3	4.9	4.7	3.7	5.1	5.2	3.9	6.8	5.2	O.O.S.	4.2	11.9	13.0	12.0	11.9	14.0
Plant Source	ug/L	15.1	12.0	7.0	NS	3.9	3.1	6.7	6.0	3.7	5.6	7.6	4.8	8.3	8.3	11.0	10.0	8.3	10.8
Plant Tap	ug/L	BDL	BDL	BDL	NS	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL

BDL - Below Detection Level

Arsenic - Primary MCL 10.0 ug/L

Lab detection level - 3.0 ug/L

O.O.S. - Out of Service